



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Sample analysis report of samples collected from "MDH International School" Plot no 03, Pocket - 02, Sector-06, Dwarka, New Delhi - 110075 Vide challan no: - 113 dated: - 24.07.2025.

S1: DJB Stored water at above site.

S2: Drinking Point (R.O) at above site.

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY

S. No.	Particulars	Limit		S1	S2	
		Acceptable	Permissible			
THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY.						
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	28.07.25	28.07.25
2.	Date of Analysis	-----	--	--	30.07.25	30.07.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	3.4	2.4
6.	PH value	-----	6.5	8.5	7.5	7.48
7.	Electrical Conductivity	µmho/cm	--	--	223	245.8
8.	Total dissolved solids	mg/l	500	2000	145	159.8
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	70	74
11.	Total Hardness	mg/l	200	600	98	110
12.	Calcium Hardness	mg/l	--	--	54	70
13.	Magnesium Hardness	mg/l	--	--	44	40
14.	Calcium as Ca	mg/l	75	200	21.6	28
15.	Magnesium as Mg	mg/l	30	100	10.56	9.60
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	3.0	2.8
19.	Sulphate	mg/l	200	400	20	26
20.	Chloride	mg/l	250	1000	16	18
21.	Fluoride	mg/l	1	1.50	0.34	0.28
22.	Dissolve Iron	mg/l	1	N.R.	0.14	0.16
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.60	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS: As per tested parameters Sample S-1 & S-2 can be used for drinking purpose.


S. Pandey
Asstt. Q.C.W.A. Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

Sumit
BACT.

For
A/CHEMIST



MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D- 582

Dated- 02/07/2025

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - MDH INTERNATIONAL SCHOOL
2. SCHOOL ADDRESS:- Plot No. 3, Pkt-2, Sec-6 Dwarka, New Delhi-110075.
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS- 718 GIRLS – 603 TOTAL = 1321
5. NO. OF STAFFS: MALE -07 FEMALE – 53 TOTAL = 60


Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Deputy Health Officer
Deputy Health Officer
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)